



Procedure For Leak Testing of In-Service Equipment

AZSPU-HSSE-DOC-00055-2

This document supersedes **UNIF-HSE-PRO-241-C2**

Authority:	AzSPU Safety & Compliance Systems Manager Yuliy Zaytsev	Custodian:	HSE Systems – Control of Work Advisor Niyaz Mamedov
Scope:	AzSPU	Document Administrator:	Document Asset Technician
Issue Date:	09 September 2004	Issuing Dept:	Safety & Compliance Systems
Revision Date:	23 April 2009	Control Tier:	2
Next Review Date:	23 October 2010		

TABLE OF CONTENTS

1	INTRODUCTION.....	4
1.1	PURPOSE.....	4
1.2	SCOPE.....	4
1.3	LEGISLATION & STANDARDS.....	4
1.4	COMPANY REQUIREMENTS.....	5
1.5	STOPPING UNSAFE WORK.....	5
1.6	DEVIATIONS.....	5
1.8	NORMATIVE REFERENCES.....	5
1.9	LANGUAGE FACILITATION.....	6
2	ROLES AND RESPONSIBILITIES.....	6
2.1	OFFSHORE INSTALLATION MANAGER / SITE MANAGER / SITE CONTROLLER.....	6
2.2	AREA AUTHORITY.....	6
2.3	PERFORMING AUTHORITY.....	7
2.4	EMPLOYEES.....	7
3	COMPETENCY, TRAINING AND AWARENESS.....	7
3.1	COMPETENCY.....	7
3.2	UNDERSTANDING.....	8
3.3	AWARENESS.....	8
3.4	NEW INDIVIDUALS.....	8
4	SELECTION OF TEST TYPE.....	8
4.1	GENERAL.....	8
4.2	HYDRAULIC.....	9
4.3	NITROGEN.....	9
4.4	LIQUID FILL AND NITROGEN SQUEEZE.....	9
4.5	NITROGEN – HELIUM.....	9
4.6	SERVICE.....	10
4.7	POST-TEST INTEGRITY CHECKS.....	10
5	LEAK TESTING GUIDELINES.....	11
5.1	COMMUNICATION.....	11
5.2	TEST AREA ACCESS.....	11
5.3	TEST EQUIPMENT.....	11
5.4	TEST BOUNDARY.....	11
5.5	ISOLATIONS.....	12
5.6	VENTS AND SAFETY VALVES.....	12
5.7	APPLYING THE TEST.....	12
5.8	MONITORING AND INSPECTION.....	13
5.9	DEPRESSURISING AND RETURN TO SERVICE.....	13
5.10	REPAIRS OR ADDITIONS AFTER LEAK TESTING.....	13
5.11	SAFETY CONSIDERATIONS IN NITROGEN LEAK TESTING.....	14
6	RECORDS (CERTIFICATION).....	15
7	REGISTERS.....	15
8	CONTRACTORS.....	15
9	AUDIT AND REVIEW.....	15
	APPENDIX A – LIST OF DEFINITIONS.....	16
	APPENDIX B – LEAK TESTING CHECKLIST.....	18
	APPENDIX C – GUIDANCE NOTES.....	20

REVISION/REVIEW LOG.....	22
---------------------------------	-----------

1 INTRODUCTION

1.1 PURPOSE

The purpose of this document is to provide:

- Guidelines for assessing the risks and establishing the precautions to be taken when carrying out leak testing of in-service equipment.
- Information that may be used as the basis for producing formal instructions for specific pressure and leak testing activities.

Prior to re-instatement of plant or equipment, any leak testing operations shall be conducted in accordance with this procedure.

A leak test (hydraulic where practicable) is performed to prove the pressure tightness (i.e. fitness for service) of joints, seals and glands etc, whenever the integrity of containment systems has been broken, either at hook-up/commissioning or post-operations phase. The prevention of even minor leaks is vitally important where flammable or toxic fluids are concerned.

Leak testing is carried out at a pressure of 110% of the maximum operating pressure (MOP), or 95% PSV set pressure if PSV is provided in the system.

1.2 SCOPE

This applies to all leak testing operations carried out on BP owned and managed sites and installations in AzSPU. This procedure does not include standard strength tests which are conducted on individual items of equipment/systems. These tests are carried out to separate item design code requirements, and are completed before the items are installed as part of the overall pressure retaining system. e.g. pressure vessels, valves etc. Contractors working on BP owned or managed sites / installations are also responsible for alignment with this procedure.

This procedure contributes to compliance with the “HSE expectations” contained in “getting HSE right”, the ‘Golden Rules of Safety’ and the Control of Work (CoW) standard that the Hazards associated with BP activities are identified and that the risks are assessed and managed.

All guidelines contained shall be regarded as the minimum requirements for BP owned or managed sites / installations in Azerbaijan and Georgia.

The scope covers defined activities of BP and Contractors at all BP AzSPU sites and installations.

1.3 LEGISLATION & STANDARDS

The aim of this Safe System of Work is to achieve “no accidents”, “no harm to people” and “no damage to the environment”. To achieve this aim, this SSOW complies with National Legislation, the terms of the Production Sharing Agreement (PSA) and mandatory BP Standards.

The best International Oil Industry practice has been adopted to reduce the level of risk to ALARP.

In the absence of local regulations, BP Group Standards will apply. In addition, appropriate UK and US regulations and industry best practice have been considered in setting suitable goals and targets.

1.4 COMPANY REQUIREMENTS

It is a company requirement that all tasks are subjected to an assessment of risk to demonstrate that risks have been reduced to as low a level as reasonably practicable (ALARP). This can be achieved by complying with the Company's existing standards. Where compliance with Company standards cannot reasonably be achieved, a formal Level 2 Risk Assessment will be undertaken to identify any additional controls and demonstrate that risks remain as low as reasonably practicable. Whether by compliance with Company Standards or through Level 2 Risk Assessment, the Company's Golden Rules of Safety must be complied with. Golden Rules are non-negotiable.

1.5 STOPPING UNSAFE WORK

To stop the continuation of potentially unsafe work at the earliest possible stage, the Control of Work (CoW) Policy and this procedure for Leak Testing make it very clear that all personnel are obliged and have the authority to "**STOP**" the work that they consider to be unsafe.

1.6 DEVIATIONS

This procedure is written in sufficient detail that it should be able to be applied consistently at all sites / installations. There may still be the requirement for some local rules covering site / installation specific logistical/administrative arrangements and local variations in responsibilities to reflect differences in organisational arrangements. These local rules should not deviate from the core processes within this document. Any form of deviation from this procedure, including but not limited to local rules, shall be requested and authorised in accordance with SSOW, Deviations from Regulations and Procedures (Doc. No: AZSPU-HSSE-DOC-00011-2).

1.8 NORMATIVE REFERENCES

The following normative documents contain requirements that, through reference in this text, constitute requirements of this procedure. For undated references, the latest edition of the normative document referred to applies.

American Society of Mechanical Engineers (ASME)

ASME B1.20.1	Pipe Threads, General Purpose	2006
ASME B31.3	Process Piping	2006
ASME B31.4	PIPELINE TRANSPORTATION SYSTEMS FOR LIQUID HYDROCARBONS AND OTHER LIQUIDS	2007

In addition, this procedure shall, where appropriate, be used in conjunction with the suite of BP AzSPU SSOW Procedures referenced below.

Document Number	Title of Procedure
AZSPU-HSSE-DOC-00011-2	Deviations from Regulations and Procedures
AZSPU-HSSE-DOC-00054-2	Incident Investigation and Reporting
AZSPU-HSSE-DOC-00060-2	Permit To Work
AZSPU-HSSE-DOC-00012-2	Authorisation
AZSPU-HSSE-DOC-00063-2	Task Risk Assessment
AZSPU-HSSE-DOC-00048-2	Energy Isolations-Electrical
AZSPU-HSSE-DOC-00049-2	Energy Isolations-Process
AZSPU-HSSE-DOC-00013-2	Confined Space Entry
AZSPU ENG STP 36-101-01	Bolted Joint Integrity Management

1.9 LANGUAGE FACILITATION

Due to the various languages spoken at site, there is a necessity to assist all with “an ease of understanding”. Therefore, the development and use of information tools are available.

2 ROLES AND RESPONSIBILITIES

2.1 OFFSHORE INSTALLATION MANAGER / SITE MANAGER / SITE CONTROLLER

The Site Manager / Site Controller / Offshore Installation Manager shall be responsible and accountable for the application of this procedure in their area of responsibility. They shall ensure:

- That adequate numbers of Competent responsible persons are appointed to manage and maintain the requirements of this procedure
- That only competent and authorised personnel are involved in pressure testing activities
- That this procedure is strictly adhered to for all occasions when it is identified that leak testing activities are to take place.
- That formal records of all risk assessments are maintained in accordance with this procedure
- That only suitably qualified and experienced personnel are appointed to the roles of Performing Authority, responsible engineer / person in charge of leak testing
- That formal records of all pressure tests and leak tests are maintained in accordance with this procedure

2.2 AREA AUTHORITY

The Area Authority shall:

- Be responsible for ensuring that the requirements of this procedure are adhered to for all work involving leak testing activities in his area of responsibility
- Ensure that leak testing operations comply with the guidelines within this document and/or ensure that any deviations from those guidelines are documented and authorised

2.3 PERFORMING AUTHORITY

The Performing Authority shall ensure:

- Have such practical experience and theoretical knowledge of the equipment to be tested so that he will be able to detect defects or weaknesses highlighted by the test and assess their importance to the integrity and function of the equipment. The Performing Authority must be qualified and trained to a standard sufficient to meet any applicable regulations.
- Ensure that leak testing operations comply with the guidelines within this document and/or ensure that any inability to comply with the conditions of the Permit result in a re-assessment of the task
- The compliance of all personnel under their supervision with this procedure when involved in leak testing activities
- That a risk assessment has been performed and a toolbox talk conducted
- That all personnel are informed of, and understand, the risks associated with the task they are performing, and any associated works that may affect their work activity
- That the activity is executed in accordance with this procedure
- That leak testing activities are halted if an unsafe situation occurs
- That good housekeeping practices are implemented at all work areas
- That work activities have been reviewed and pertinent information exchanged with all other affected parties

2.4 EMPLOYEES

ALL EMPLOYEES SHALL BE RESPONSIBLE FOR:

- Compliance with this procedure when involved in leak testing activities
- Implementing good housekeeping practices at the work site
- Informing their immediate Supervisor should any unsafe situation occurs
- Awareness of other personnel and ongoing works in their area

3 COMPETENCY, TRAINING AND AWARENESS

3.1 COMPETENCY

BP's employees, and those of its Contractors must provide adequate training for all personnel likely to be involved in Leak Testing, to ensure that they possess the correct levels of competency.

All individuals shall be able to and be prepared to demonstrate their levels of competency to

Control Tier: <<2>>

Revision Date: 23 April 2009

Document Number: << AZSPU-HSSE-DOC-00055-2>>

PAPER COPIES ARE UNCONTROLLED. THIS COPY VALID ONLY AT THE TIME OF PRINTING. THE CONTROLLED VERSION OF THIS DOCUMENT CAN BE FOUND AT <http://docs.bpweb.bp.com/dkazspu/component/hssesms>

the Performing Authority, Supervisor and / or Leak Test Supervisor

This shall be demonstrated through individuals understanding, knowledge and the skills necessary to safely perform their assigned duties together with certifiable evidence of their competency.

3.2 UNDERSTANDING

All individuals shall be fully conversant with the:

- Scope of work and the potential hazards associated within their scope of work to ensure that they understand the hazards of the task in hand and all associated controls
- Safe systems of work (SSOW) elements associated with their scope of work, including but not limited to: PTW, Energy Isolations., purging and / or ventilation procedures
- Relevant scope of work task risk assessments

3.3 AWARENESS

All individuals shall be fully aware of:

- What they need to do in the event of an emergency on site
- What they need to do in the event of an incident related to their scope of work
- How to use the relevant communications equipment
- Self rescue
- How to use continuous gas monitoring equipment
- All aspects of the proposed Leak Test activities with focus on their particular duties

3.4 NEW INDIVIDUALS

New individuals shall not be assigned to the above tasks, unless under training and accompanied by a competent person (maximum 2 new starts to 1 supervisor) who is familiar with the hazards of Leak Testing.

4 SELECTION OF TEST TYPE

4.1 GENERAL

A liquid medium (hydraulic) is the preferred means of testing and shall be used for leak testing wherever possible, in order to minimise the stored energy.

The preferred liquid medium is water. However, the effect of the water, and any additives, on the metallurgy of the pressure envelope, and the effect of any residual water/additives on the process (eg formation of hydrates), shall be considered (eg when testing austenitic stainless steels, the water should be distilled or demineralised and contain <30ppm of chloride ions).

Selection of liquids other than water should take account of:

- The possibility of explosion resulting from the 'diesel' effect
- The boiling point relative to the test temperature

The flammability of the liquid, the flash point of which should not be less than 65°C, and at least 10°C above the maximum test temperature.

4.2 HYDRAULIC

- Weight must be considered, particularly in context of equipment support e.g. pipe hangers, foundations
- Care must be taken with draining the test fluid on completion – in some cases the equipment may require flushing and/or drying.
- Some test fluids, typically water, may be incompatible with equipment materials
- Generally considered to be a "safe" test medium due to low levels of stored energy
- Internal leakage, e.g. through valves at the boundary, may require continuous pressuring of the equipment. In severe cases this can prevent a successful test
- Detection of leakage is typically by observation of fluids leaking to atmosphere at joints/connections under test. In cases where joints/connections are not visible then pressure drop off can be used as an indicator.

4.3 NITROGEN

Note! Pneumatic leak-testing should not be carried out before the integrity of the equipment has been confirmed by a standard pressure test.

- Relatively high levels of stored energy
- Large volumes may require supply of bulk nitrogen
- Considerable time may be needed to pressurize and/or vent
- Vent location(s) must be carefully selected so as to avoid any risk of asphyxiation to personnel
- Detection of leakage is typically by means of bubble test at joints/connections.

4.4 LIQUID FILL AND NITROGEN SQUEEZE

Combination of both sets of attributes mentioned in sub sections 4.2 and 4.3.

4.5 NITROGEN – HELIUM

- Addition of a small proportion of helium (known as a tracer) enhances the searching qualities of nitrogen. Normally 99% nitrogen, 1% helium.
- Typically supplied in bulk by a specialist contractor. Usually used for large-volume tests e.g. post shutdown
- Detection - Requires specialist detection equipment - can give a quantitative output

4.6 SERVICE

For **process hydrocarbon systems**, although it is not the preferred means of testing, under certain conditions it may be considered appropriate to carry out testing with the service fluid (ie liquid or gas) rather than with water, nitrogen or some other medium. This should only be considered where it can be clearly demonstrated that it is impractical to carry out leak testing due to the configuration of the system and that the hazards associated with the introduction of high-pressure testing equipment etc would be greater than the hazards associated with the service testing.

Where this method is proposed, a written justification must be recorded on a Level 2 Risk Assessment.

The following criteria and precautions should be considered as the minimum in support of carrying out service tests on hydrocarbon system;

- The number of joints that have been broken shall be small to guarantee the ability to control and monitor the test.
- A competent technician shall have witnessed the joints being re-made in accordance with the Guidance on Certification (GOC) Procedure for Critical Joint Installation.
- Pressurisation should be controlled via a designated pressurisation route where possible, e.g. a small bore line fitted with a globe valve.
- Pressurisation shall be in small incremental steps (5.bar max) where possible.
- Depressurisation routes shall be specified and if possible both local/manual depressurisation and remote depressurisation from the control room shall be designed into the leak boundaries.
- The boundary isolation valves for the service test shall be controlled under the ISSOW isolation control.

Once it has been decided to carry out a service test, a formal procedure shall be developed including marked-up P & ID's defining the service test and detailing compliance with the above criteria.

4.7 POST-TEST INTEGRITY CHECKS

After hydrocarbons or hazardous utilities have been introduced, an initial visual check of joint integrity shall be made for all broken joints and any other joints that may have been disturbed. Further checks shall be carried out every 12 hours until the plant has reached its normal operating pressure and temperature. Checks shall be carried out for at least 2 days.

Note: Where a service test has been completed on a hydrocarbon system, these post-test integrity checks must be repeated at each pressure increase of 5 barg above the original service test pressure.

5 LEAK TESTING GUIDELINES

5.1 COMMUNICATION

- Effective communication must be established between sites whenever the test envelope extends beyond one site, for example, pipelines.

5.2 TEST AREA ACCESS

Access to the test area shall be limited to essential personnel only. In particular, before the test commences compliance is required with the following points:

- The area shall be cordoned off (using tape, shields or barriers, etc) at an adequate distance from the equipment to be tested,
- Warning signs and barriers shall be posted at access ways, at other strategic positions, and on the equipment to be tested (including the doors of test workshops or other designated areas.
- Wherever possible, warnings of an imminent pressure test shall be broadcast.
- When testing, the test area boundaries shall be patrolled to ensure that no unauthorised personnel enter the area.

5.3 TEST EQUIPMENT

- Pressuring equipment shall be provided with suitably calibrated pressure control / regulator devices.
- Suitably calibrated pressure indicating device(s) shall be provided in a location clearly visible to the person controlling the pressure. Account should be taken of pressure variation caused by elevation changes inside the envelope.
- Pressuring equipment and plant/equipment shall not be left unattended at any time during the test.
- Pressuring equipment shall be isolated from the equipment under test and where practicable disconnected, when the test pressure has been reached. The pressurising valve should be locked in the closed position.
- All hoses are fully secured with tie-down devices capable of withstanding the forces used in the test. Each hose end is to be fitted with whip check cables.

5.4 TEST BOUNDARY

- A Competent Person shall inspect the equipment to be tested, prior to testing, to ensure the equipment is free from any obvious flaws
- Within the test boundary, there should be an accessible and operable means of quickly and safely de-pressuring the test in the event of equipment failure etc.
- Prior to any hydraulic pressure test taking place it must be established that the foundation and supports of the equipment under test are rated and capable of withstanding the combined weight of the equipment and the liquid required to fill it.

- The volume of equipment under test must be kept as small as possible so to minimise the stored energy within the pressurised system.
- Hazard and risk identification shall, as a minimum, consider:
 - the stability of components such as expansion joints and spring hangers
 - any interfaces with lower pressure systems or equipment (including heat exchangers, gauges, instruments etc) and must ensure measures are in place to ensure that such systems cannot be over-pressurised
 - any connected high pressure equipment such as pulsation dampers and accumulators.

5.5 ISOLATIONS

- Blanking devices such as spades, blinds and screwed plugs, etc. shall conform to the equipment specification. All plugs must have a minimum thread engagement length as per ASME B1.20.1.
- Where testing is carried out against closed valves it must be assumed that the valves leak, and downstream equipment must be protected against subsequent over pressuring. This should be done by opening of suitable vents or by monitoring of downstream pressures

5.6 VENTS AND SAFETY VALVES

- Where the source pressure of the pressurising medium is greater than the test pressure, a safety valve should be fitted to the equipment/system being tested, set to relieve at a pressure that will prevent over pressurisation.
- Sufficient venting / draining points shall be provided in order to prevent trapping of pressurising medium behind non-return valves, check valves, between isolation valves, or within dead legs of the pressure envelope.
- When filling equipment/plant, adequate venting must take place at all high points or dead ends to release entrapped gas.

5.7 APPLYING THE TEST

- Pressure must be increased gradually to the final pressure, and sufficient time should be allowed for equipment and test medium to reach equilibrium.
 - Raise pressure to 25% test pressure and allow to settle.
 - Increase to 50% test pressure.
 - Increase to 75% test pressure.
 - Final increase to the full test pressure.
- The pressure should be maintained sufficiently long for an Inspection Engineer to examine the entire system, and for any defects to have time to manifest themselves.
- Equipment must not be subjected to any form of shock loading during testing.
- When any equipment/plant is left under pressure for decay or leak observation, consideration must be given to the ambient temperature changes, particularly in respect to thermal expansion of liquids in a closed system.

5.8 MONITORING AND INSPECTION

- Pressure monitoring shall extend to any adjacent systems that are not positively isolated.
- Close examination of equipment at above design pressure shall not take place until the pressure has been held for 30 minutes. In any event, extreme care should be exercised until the pressure has been reduced to the design pressure.
- If an inspection is required within the hold period, then pressure should be reduced to the Design Pressure.

5.9 DEPRESSURISING AND RETURN TO SERVICE

- Extreme care shall be taken to ensure that all pressure has been relieved before opening any system that has been subject to pressure or leak test.
- On completion of the test, the pressure shall be reduced gradually and under controlled conditions until approximately atmospheric pressure is reached. More rapid draining of the test fluid can then take place.
- When draining equipment, adequate vents at the highest point must be opened to prevent drawing a vacuum. The drainage system must be capable of handling the flow from the pressurized equipment/plant without itself over pressuring.
- Consideration must be given to the possibility of test fluids being trapped behind non-return valves; it may often be necessary to vent or drain the test fluid from more than one point.
- Special consideration should be given to test fluid which may be contaminated with oil or contain corrosion inhibitor or other chemical. The method of disposal of test fluid must be included in Work Permit.
- Clamps or bolts on flanges shall not be loosened while the system is still under pressure. Clamps shall only be removed by competent personnel who have been trained in such procedures.
- Depending upon the test medium used, the return of equipment/plant back into service may produce additional hazards. In particular:
 - Residual water after draining may contaminate the product, or cause problems if the equipment is on high or low temperature service.
 - Systems containing air need to be inert prior to the introduction of process fluids.
 - Inert gas must be vented to an area where personnel cannot be affected by it.
- Consideration must be given to the flushing and preserving of systems that are not being taken back into re-use immediately.

5.10 REPAIRS OR ADDITIONS AFTER LEAK TESTING

If repairs or additions are made following the leak test, the affected piping shall be retested, except that for minor repairs or additions, the retest requirements may be waived when precautionary measures are taken to assure sound construction. (B31-345-2.6)

5.11 SAFETY CONSIDERATIONS IN NITROGEN LEAK TESTING

Nitrogen can asphyxiate, therefore great care should be taken to avoid gross leakage of nitrogen or nitrogen/helium. Particular care should be taken when opening up vessels that have been nitrogen purged or when the venting of nitrogen is taking place.

Pressure shall be introduced gradually into the system allowing adequate time for temperature equalisation; in this respect special attention is drawn to the cooling Joule-Thompson effect which occurs when letting down high-pressure nitrogen into the system to be tested. Nitrogen leak testing is performed with gases at high pressure. Therefore attention is drawn to the hazards of a possible release, with explosive force, of energy stored in the system. Systems under test shall be depressurised prior to bolt re-tightening, tensioning or other remedial action to improve leaks, the only exceptions to this being valve glands, which may be adjusted but not re-packed whilst the system is still pressurised.

The possibility of brittle fracture shall be considered when conducting a nitrogen leak test at metal temperatures near the ductile/brittle transition temperature of the steel. It is recommended that nitrogen leak testing should not be carried out when the ambient temperature is below 7°C on equipment and piping constructed from non-impact tested carbon steel materials with nominal thickness of $>3/4$ in (19mm), (ie API 5L, A 106, A 105, A 216, etc). For non-impact tested carbon steel materials with nominal thickness $>3/4$ in, a Competent Person shall specify the minimum metal temperatures for leak testing, based on requirements of either RP 42-1 or BS 5500. Sites are advised to identify any systems containing non-impact tested carbon steel and prepare the appropriate local test procedures.

Introducing nitrogen to a system introduces a large energy source, far greater than the energy stored in an equivalent liquid leak test. To minimise this stored energy, vessels which normally operate with a liquid level should be water filled (ensure water filling of the vessel is acceptable with respect to corrosion and scaling) prior to pressurising with nitrogen.

When a specialist contractor is contracted to carry out nitrogen leak testing rather than leak testing with nitrogen quads or low volume pumps the following additional measures apply:

- There will be a Pump Operator who will be in radio contact with the Leak Test Supervisor who will monitor system pressure. The pumping unit will be manually shut down on the instruction of the Leak Test Supervisor. The leak test crew should have a written procedure for radio protocol
- There will be an automatic pump trip (Overpressure Protection Device (OPPD)) that will shut down the pumping unit. The OPPD will be located close to the injection point so that it can monitor the highest pressure that will be seen in the Installation system
- Full flow (of test medium injection rate) pressure relief will be available via Pressure Safety Valves (PSVs). It is acceptable and appropriate for the PSVs on the Installation system/plant to be used for this purpose. However, if full flow pressure relief is not available via a plant system, then Full flow pressure relief will be available via Pressure Safety Valves (PSVs). It is acceptable and appropriate for the PSVs on the Installation system/plant to be used for this purpose. However, if full flow pressure relief is not available via a plant system, then consideration should be given to the use of temporary PSVs supplied by the leak test contractor. Any system PSV's used for this purpose shall be within their re-certification date. Any contractor supplied PSV's shall be certified and calibrated, with certification available for examination at site. If full flow pressure relief is not provided, then a Level 2 Risk Assessment should be completed and assurance gained that there is sufficient

control in place to manage the HP/LP interface

- If it has been identified that the leak test contractor will have to supply PSVs, consideration should be given to the location that these PSVs would vent to in an emergency. The vent location should be surveyed and approved by the Installation Area Authority with guidance from the leak test contractor on expected nitrogen plume
- Contractor Method Statement shall be thoroughly examined and approved

6 RECORDS (CERTIFICATION)

All pressure / leak test results shall be formally certificated and recorded where necessary and all certificates included with the relevant equipment records.

7 REGISTERS

A register will be held on site of all personnel deemed competent for all the roles associated with Leak testing, and will be managed by the Site Manager / Site Controller / Offshore Installation Manager.

8 CONTRACTORS

In cases where leak testing is contracted to a specialist third party, the contract shall, as a minimum, specify the need to observe the requirements of this procedure and in addition the:

- Roles and responsibilities of the relevant BP and contractor personnel
- Authority for approval of procedures
- Required competency of the contractor personnel and the means of controlling compliance
- Keeping of test records
- Means of monitoring the contractor's safety management system.

9 AUDIT AND REVIEW

Business Units shall periodically review pressure and leak testing activities to verify general compliance with this procedure and with any local procedures. Such reviews shall include checks to verify compliance with any statutory requirements for periodic strength tests of equipment to demonstrate its continued fitness for service.

Independent audit of pressure / leak testing procedures and records shall be undertaken periodically at the request of the Site Manager / Site Controller / Offshore Installation Manager.

APPENDIX A – LIST OF DEFINITIONS

In-Service Equipment	Equipment installed as part of a system, the individual components of which have been subject to Codal Pressure/Strength Testing. This applies to equipment included in systems where the integrity of containment has been broken, either at hook-up/commissioning or post-operations phase.
Blank / Blanking:	Installation of a piping specification rated device such as a blind flange, spade or spectacle blind for the purpose of achieving positive isolation.
Boundary isolations:	Isolations that define the boundaries of a discrete pressure envelope.
Competent Person:	<p>A person having such practical experience and theoretical knowledge of the equipment to be pressure tested so that he will be able to detect defects or weaknesses highlighted by the pressure test and assess their importance to the strength and function of the equipment.</p> <p>Competent Persons must be qualified and trained to a standard sufficient to meet any applicable regulations.</p>
Design Pressure	The maximum pressure at which the system is designed to operate at. This is usually the maximum operating pressure plus a small margin (typically 10%).
Leak test:	Application of pressure to a system in which the integrity of individual components has already been proven by a pressure test so as to identify leakage and leakage rates from component connections, valves etc. Leak testing is carried out at a pressure of 110% of the maximum operating pressure (MOP), or 95% PSV set pressure if PSV is provided in the system.
Local procedures:	Site specific or Business Unit specific procedures that address the arrangements in place for the implementation of recommended and statutory practices.
Maximum Operating Pressure (MOP)	The maximum pressure expected during normal systems operation.
Maximum Allowable Working Pressure	The maximum pressure which a component can safely withstand. Note that this is often greater than the design pressure, due to components being manufactured from thicker material than that required for the design pressure.
Pressure/ Strength test:	A test involving the application of pressure to a system so as to apply a load greater than the maximum load generated in service but less than would cause physical damage. The test provides evidence that the system can safely withstand the service pressure. Test pressures may vary between individual components within the same system due to differing codal design requirements.
Initial Service leak test:	A leak test undertaken when a system is brought into normal service, completed at operating pressure for Category D fluids only (refer to ASME B31.3 para 300.2).

APPENDIX B – LEAK TESTING CHECKLIST

A checklist to be used when planning leak tests is provided in Figure 1 below as a guide.

Note: This checklist in this appendix is provided as an *aide memoir* only, and is not intended for use as an approved test certificate or an official document:

Leak/Pressure Testing Checklist												
1. TYPE OF TEST:		STANDARD PRESSURE TEST:				LEAK PRESSURE TEST:						
2. TESTING MEDIUM:		HYDRAULIC:				PNEUMATIC:						
3. EQUIPMENT TO BE TESTED:												
Codal Test Pressure (strength test)						Proposed Test Pressure:						
Maximum Operating Pressure (leak test)												
Incremental steps (%):						Duration each step:						
Duration of Test Pressure:						Written procedure provided:		YES		NO		
All threaded connectors, plugs, and caps secure and tight:						YES			NO			
All attachments unable to withstand Test pressure removed or isolated:						YES			NO			
Quality:						Temperature:						
4. TEST ENVELOPE INSPECTION:						Visual	YES		NO		MPI: YES	NO
Radiography:		YES		NO		Other (specify):			YES		NO	
5. EQUIPMENT ISOLATED AT:						and at:						
6. PRE-TEST PREPARATIONS:												
Equipment vented for filling at:						and at:						
Check facilities for venting trapped pressure from NRVs or between isolation valves						YES			NO			
Vents now SHUT						YES			NO			
Safety valves set to prevent test pressure being exceeded						YES			NO			
Calibrated test pressure gauge(s) fitted and visible to operator						YES			NO			
Any pipe support / expansion joints fitted with temporary restraints						YES			NO			
Pressuring equipment fitted with regulator and relief valve and is in sound condition						YES			NO			
Methods for upstream and downstream monitoring are in place						YES			NO			
Warning signs posted, barriers erected, and sentries in place						YES			NO			
PA announcement of proposed test has been organised / made						YES			NO			
7. ON COMPLETION OF TEST:												
Vents are open for slow depressurisation at:												
and at:												
Drains are open for draining of test medium at:												
and at:												
8. EQUIPMENT HAS BEEN RETURNED TO PRE-TEST EXCEPT FOR:												
and:						YES			NO			
9. CHECKLIST COMPLETED BY:												
Name:						Signature:						
Title:						Date:						
Control Tier: <<2>> COMPETENT PERSON												
Revision Date: 23 April 2009												
Document Number: << AZSPU-HSSE-DOC-00055-2>>												

<p>Test Plan / Programme</p> <ul style="list-style-type: none"> <input type="checkbox"/> If any pipeline or plant configuration changes then a MoC and relevant TA approval are required <input type="checkbox"/> Design Pressure or Maximum Operating Pressure (MOP) defined <input type="checkbox"/> Test Pressure defined <input type="checkbox"/> Marked up P&ID's produced showing test boundaries <input type="checkbox"/> Written test procedure developed <input type="checkbox"/> Test medium selected (hydraulic considered rather than pneumatic) <input type="checkbox"/> If pneumatic test planned, consider reducing the volume by water filling vessels <input type="checkbox"/> Emergency depressurisation route identified <input type="checkbox"/> Pressurisation / depressurisation procedures take account of the position of non-return valves <input type="checkbox"/> Pressurisation procedure specifies hold points (25%, 50%, 75% of the test pressure)
<p>Pre-test Preparation and Equipment Checks</p> <ul style="list-style-type: none"> <input type="checkbox"/> All threaded connections, plugs and caps are secure <input type="checkbox"/> All attachments unable to withstand test pressure are removed/ isolated <input type="checkbox"/> Facilities have been checked for means of venting trapped pressure <input type="checkbox"/> Safety valve set to prevent test pressure being exceeded <input type="checkbox"/> Calibrated test pressure gauge(s) fitted and visible to operator <input type="checkbox"/> Any pipe supports/expansion joints fitted with restraints <input type="checkbox"/> Pressure equipment is fitted with regulator and relief valve and is in sound condition <input type="checkbox"/> Methods of upstream and downstream monitoring are in place <input type="checkbox"/> Warning signs and barriers erected <input type="checkbox"/> PA announcement of proposed test has been organised <input type="checkbox"/> Contingencies for leakage have been made <input type="checkbox"/> Overpressure protection device in place for specialist contractor nitrogen testing <input type="checkbox"/> Pumping unit connected to ESD system where required
<p>Post-test Checks</p> <ul style="list-style-type: none"> <input type="checkbox"/> Vents to be opened at high points during liquid depressurisation <input type="checkbox"/> Pressure to be released gradually <input type="checkbox"/> Inert gases vented to flare or alternatively to a safe area <input type="checkbox"/> Confirm that there is no trapped pressure within test envelope

Figure 1. Leak Testing Checklist

APPENDIX C – GUIDANCE NOTES

Leak Testing Acceptance Criteria

This section defines the allowable leak rates for different test medium and equipment type and duty.

Acceptance Criteria for Hydraulic Testing

For hydraulic testing using water the test should be conducted for a minimum of 30 minutes. A test should be deemed successful if no significant reduction in pressure is observed over the test period and all joints and connections have been visually inspected for leakage. In some cases it may not be possible to maintain a constant test pressure due to trapped air in the system or passing valves. In this case the visual inspection is vital in confirming an acceptable test.

Acceptance Criteria for Nitrogen Testing

For nitrogen testing, depending on the scope of the test, there are two primary means of confirming an acceptable test. These are:

- Bubble testing
- Leak rate measurement using a helium tracer

Helium tracer testing is normally used for large scale testing of plant or the installation of new equipment involving a specialist contractor. Bubble testing is normally applicable when carrying out smaller scale testing using nitrogen quads.

Bubble Testing Criteria for Hydrocarbons

Bubble Testing Method	Acceptance Criteria
Method 1 involves the application of a leak detection fluid e.g 'Snoop' to the joint and monitoring for surface bubbles. For all large diameter flanges (>6" NB), the joint should be taped and the leak detection fluid applied to a pin hole in the tape.	No presence of continuous bubble growth detected in 60 seconds for flanges up to and including 4in NB and 90 seconds for flanges above 4in NB.
Method 2 involves taping the joint and inserting a 1/4in diameter tube from the flange into a water bucket and monitoring the number of bubbles released.	5 bubbles/min.

Note: 5 bubbles/min approximates to 15scf/year from a 1/4in tube.

Helium Tracer Testing

Leak rate measurement in the case of helium tracer testing involves taping of individual flanges and measurement of leakage using a measurement probe. The following leakage criteria apply:

Leakage Rates (scf/yr)			
Helium Tracer Testing Method	Acceptance Criteria (scf/year)		
	Target		Maximum
	Closed Module	Open Module	
Oil	100	200	400
Gas <50barg	50	100	200
Gas >50barg	20	40	100

Acceptance of leak rates in the range between target and maximum allowable leakage is by exception only and review by the appropriate Technical Authority. The review shall take into account fluid type, location of joint and ventilation and subsequent monitoring programme.

REVISION/REVIEW LOG

Revision Date	Authority	Custodian	Revision Details
9 September 2004	Alan McNulty	Esmira Akhundova	Initial Issue
08 April 2008	Alan McNulty (AzSPU CH&S Manager)	Abbas Islamov (Central Safety TL)	<p>General.</p> <p>Section 1. Introduction. Four new paragraphs are added to Section 1:</p> <p>1.3 Legislation & Standards 1.4 Company Requirements 1.5 Stopping Unsafe Work 1.6 Deviations SSOW Specific Cross References paragraph 1.5 is now Normative References 1.8</p> <p>Section 2. Roles and Responsibilities. New paragraph is added 2.4 Employees</p> <p>Section 4. Responsibilities. New paragraph is added 4.7 Post-Test Integrity Checks</p> <p>Section 5. Leak Testing Guidelines. New paragraph is added 5.10 Repairs or additions after leak testing.</p> <p>Appendix D. New appendix provides opportunity for quick feedbacks and/or improvement suggestions.</p>
05 December 2008	Yuliy Zaytsev Safety & Compliance Systems Manager	Adalat Mamedov Central Safety TL	Authority position/name and custodian name have changed to reflect org changes in HSE&TD.
23 April 2009	Yuliy Zaytsev Safety & Compliance Systems Manager	Niyaz Mamedov HSE Systems – Control of Work Advisor	Additional alteration made to Paragraph 1.1 in regard to the maximum operating pressure (MOP) and PSV. The same issue is accordingly reflected in Appendix A – List of Definitions.

